

## SelectCell 120V-144V DC Lithium Battery System accessories 01/05/2023

005396	PCC144M2000 Manager	TBC	TBC	TBC
101652	24V DC Bus cable	Used to connect DC power from Worker cabinets to Manager cabinet	1 per worker cabinet	
101650	3M RJ45 Comms cable	RJ45 communications cable from end of a battery series string to next battery string or to PCC Single or Worker cabinet.	1 per Series battery string	
101637	Harting cable 1M	Pre terminated cable with Harting connectors to connect vertically stacked batteries. 50mm <sup>2</sup> .	One per vertically stacked battery. Use 101638 plus installer supplied cable to make your own cable from last battery to PCC cabinet	2kg
101670	Harting cable 0.3M	Pre terminated cable with Harting connectors to connect horizontally configured batteries. 50mm <sup>2</sup> .	One per horizontally configured battery. Use 101638 plus installer supplied cable to make your own cable from last battery to PCC cabinet.	
101638	Harting connectors x 2	2 x Harting connectors to allow installer to make cable from batteries to Single or Worker Cabinet. Max cable size 50mm <sup>2</sup>	1 per Series battery string. Installer to supply cable.	
101672	RJ45 Comms cable 5M	RJ45 communications cable 5 Metres to connect Worker Cabinet to Manager Cabinet.	1 per worker cabinet	
	RJ45 Comms cable 1M	RJ45 communications cable 1M to connect from battery to battery when configured in a horizontal layout.	2 per Series Horizontal battery string. Not required if batteries are stringed vertically	
48V Version of SelectCell		Coming soon		